

DMD/NPIC-288-62
19 January 1962

MEMORANDUM FOR: Chief, Technical Planning & Development Staff, NPIC

SUBJECT: Photographic Solutions Piping Installation

1. DMD has carefully reviewed the specifications for the Photographic Solutions Piping Installation, [redacted] Naval Weapons Factory prepared by [redacted] dated 27 November 1961 and approves this specification subject to the following amendments:

a. Modify Paragraph 3.4 to read "All joints shall be sealed with a cement which strongly bonds the polyvinyl chloride", deleting "of the standard plumbing threader type".

b. Paragraph 5. Acceptance tests shall be conducted at 40 psig vice 25 psig. The system shall be filled under 40 psig pressure.

c. Drawing 2-06-001, enclosure 1 "Tabular Summary of Supply Lines", and enclosure 2 "Tabular Summary of Supply Drop Lines" shall be modified as necessary to reflect changes in the floor plan of the Photographic Laboratory as shown on drawing dated 15 January 1962.

2. DMD concurs with the [redacted] recommendation that the Photographic Solutions Piping System be installed as a part of the building contract. DMD recommends that [redacted] be instructed to prepare the necessary drawings and have the Photographic Solutions Piping System installed in accordance with their specifications dated 27 November 1961 amended per paragraph 1 above.

[redacted]
Chief, Data Management Division, NPIC

Declass Review by NGA.